



- 1 Room Thermostats**
Standard 4-wire to be run from each zone back to the corresponding manifold location.
- 2 5-wire Jumper**
5-wire to be run between each manifold location. This allows for the transfer of the clock signal, heat demand information, and power.
- 3 4-wire Jumper**
4-wire to be run from the last manifold location to the mechanical room. This allows for the transfer of heat demand information and power.

- 4 Optional**
Allow for 110V power source to a 24V transformer at each manifold location instead of supplying 24V power from the mechanical room.
- 5 Floor Sensor (optional)**
Standard 2-wire to be run from thermostat to floor sensor.