



- Drawings are for HeatLink suggested system layout only! User must determine if system layout will work for their particular application.
- Air vents, expansion tanks, pressure relief valves, etc. for heat source as per local codes.
- Use isolation ball valves for all circuits and components.
 Local codes, regulations, and authorities have final jurisdiction.

Heat Source: Boiler Panel(s): TMP085DP

Date: 2013-05-22

Heat Load(s): Radiant Heating – Dual Zones

Rough-in wiring see: SCH-MRIB-R001 Wiring detail see: SCH-TMPD-E003