



**Heat Link**<sup>®</sup>  
 www.heatlinkgroup.com  
 1-866-661-5332

**Notes:**

- Drawings are for HeatLink suggested system layout only! User must determine if system layout will work for their particular application.
- Air vents, expansion tanks, pressure relief valves, etc. for heat source as per local codes.
- Use isolation ball valves for all circuits and components.
- Local codes, regulations, and authorities have final jurisdiction.

*Heat Source:* Tankless Water Heater with Storage Tank  
*Panel(s):* TWHZ Series  
*Heat Load(s):* Radiant Heating – Up to 4 Zones  
 Date: 2013-05-22

*Schematic #:* SCH-TWHZ-M003  
*Rough-in wiring see:* SCH-MRIB-R006  
*Wiring detail see:* SCH-TWHZ-E002