



Job or Customer :			
Location :			
Engineer:			
☐Complies with Spec☐Alternate	Notes:		
Contractor:			
HeatLink Rep :			
Submitted By :		Date :	
Approved By :		Date :	
P.O. Number :		Date :	

# Description

Closed one end and 3/4" or 1" PEX insert on the other end. 1/2" branches in single row or opposing rows.

The use of PEX tubing in a potable hot-water plumbing system with an operating temperature above 140°F (60°C) or system pressure above 80 psig (550 kPaG) or highly aggressive water quality or any combination thereof can significantly reduce the service life of the tubing.

HeatLink requires following the guidelines described in Plastics Pipe Institute TN-53, Guide to Chlorine Resistance Ratings of PEX Pipes and Tubing for Potable Water Applications and HeatLink INFO 37, Domestic Hot Water Recirculation Systems.

ъ.	•		, ,	
Dim	ensions	ın/	mm)	
	C11310113	/	( ,	

Qty	Stk.#	# of ports	Inlet	Outlet	Α	В	Weight
	13203	3	3⁄4"	closed	5.43" (138 mm)	0.71" (18 mm)	0.117 lb (0.053 kg)
	13204	4	3⁄4"	closed	7.20" (183 mm)	0.71" (18 mm)	0.148 lb (0.067 kg)
	13206	6	3⁄4"	closed	10.75" (273 mm)	0.71" (18 mm)	0.227 lb (0.103 kg)
	13208	8	3⁄4"	closed	14.29" (363 mm)	0.71" (18 mm)	0.295 lb (0.134 kg)
	13806	6	1"	closed	10.75" (273 mm)	0.86" (21.8 mm)	0.216 lb (0.098 kg)
	13808	8	1"	closed	14.29" (363 mm)	0.86" (21.8 mm)	0.284 lb (0.129 kg)
	13833	3+3	1"	closed	5.43" (138 mm)	0.86" (21.8 mm)	0.132 lb (0.060 kg)
	13844	4+4	1"	closed	7.20" (183 mm)	0.86" (21.8 mm)	0.165 lb (0.075 kg)

## **Technical Data**

# **Specifications**

Material	Modified Polyphenylsulfone
Operating Pressure rating	180°F @ 100psi (82.2°C @ 0.69MPa)

#### Installation

Installation must follow all of HeatLink's instructions and guidelines.

## **Related Documents**

- PEX-a F1960 Potable Water Expansion System Installation Guide (L3240)
- HeatLink Limited Plumbing Warranty



